

**Cartersville Fire Department
P.O. Box 1390
Cartersville, GA 30120
770-387-5635
770-387-7413 (Fax)**

**New Business
Life Safety Checklist**

Name of Facility _____ Date _____

Address _____

Emergency Contact Name and Phone # _____

	Yes	No	N/A	Remarks Section
Street Address Posted (4" min.)				
Fire walls or partitions have no penetrations				
Exit are Marked & Signs Lit				
Emergency Lighting Operable				
Exit Doors are Clear & Unlocked				
Electrical Room Clear & Accessible				
No Extension Cords				
All electrical switches and outlets are covered				
No open empty spaces in panel box				
Compressed gas cylinders are secured				
Portable Fire Extinguishers Maintained & Tagged (min. 5lb. ABC)(serviced yearly)				
Gas fired water heater has min. of 3' clearance all around from combustibles				
Storage- not blocking exits, panel boxes, etc.				
Sprinkler System Maintained & Tagged (serviced yearly)				
Hood System Maintained & Tagged – (Every 6 Months)				

A Knox Box will be required for all new businesses, changes of ownership, and renovations over 50% before a business license can be issued. It is the responsibility of the applicant to install the Knox Box per the city ordinance. The box may be ordered online at www.knoxbox.com or a paper order form can be requested from the Fire Prevention Division at Cartersville Public Safety Headquarters 195 Cassville Rd. Cartersville, GA. 30120 or Phone 770-387-5635.

Fulfilling the requirements of this form does not ensure that a business license will be issued. This form is meant to help new business owners with the Cartersville Fire Prevention Division inspection process and is not an all inclusive form.